

PAT Report Passes For all Sites and Locations

CLIENT DETAILS	
Company Name:	Hair & Beauty Salon
Address:	Address 1 Address 2



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	Testsafe Ltd
Address:	Bretby Business Park Ashby Road Burton on Trent DE15 0YZ
Telephone:	01283 229873
Fax:	
Email:	sales@test-safe.co.uk
Cert Number:	
Order Number:	
File Name:	Tantone Hair & Beauty_TS20698.PAT
Signature:	

APPLIANCE DETAILS AND TEST RESULTS

Key P = PASS / F = FAIL / S = SKIP (or test not applicable)											
Appliance Id	Appliance Description	Test Date	Retest Due	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
HAIR & BEAUTY - FACIAL ROOM											
SF017466	4WAY EXTN LEAD	06/10/20	06/10/21	P	P	P 0.05	P >199	S	S	PASS	
SF017467	FOOT SPA	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS	
SF017468	TOWEL STEAMER	06/10/20	06/10/21	P	S	P 0.13	P >199	S	S	PASS	
SF017469	TABLE LAMP	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS	
SF017470	FACIAL STEAMER	06/10/20	06/10/21	P	S	P 0.25	P >199	S	S	PASS	
										Total Appliances >	5
HAIR & BEAUTY - IPL ROOM											
SF017471	6WAY EXTN LEAD	06/10/20	06/10/21	P	P	P 0.09	P >199	S	S	PASS	
SF017472	RADIO	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS	
SF017473	IEC LEAD	06/10/20	06/10/21	P	P	P 0.12	P >199	S	S	PASS	
SF017474	IPL MACHINE	06/10/20	06/10/21	P	S	P 0.12	P 94.00	S	S	PASS	
SF017475	TREATMENT BED PSU	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS	
										Total Appliances >	5
HAIR & BEAUTY - KITCHEN											
SF017488	FRIDGE	06/10/20	06/10/21	P	S	P 0.07	P >199	S	S	PASS	
SF017489	KETTLE	06/10/20	06/10/21	P	S	P 0.09	P >199	S	S	PASS	
SF017490	MICROWAVE	06/10/20	06/10/21	P	S	P 0.13	P 169.00	S	S	PASS	
SF017491	VACUUM	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS	
										Total Appliances >	4
HAIR & BEAUTY - SALON											
SF017455	PORTABLE HEATER	06/10/20	06/10/21	P	S	P 0.12	P >199	S	S	PASS	

APPLIANCE DETAILS AND TEST RESULTS
Key

P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Retest Due	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (KVA)	Leakage (mA)	Overall Status
SF017456	FIG 8 LEAD	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017457	DC PSU	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017458	IEC LEAD	06/10/20	06/10/21	P	P	P 0.05	P >199	S	S	PASS
SF017459	DC PSU	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017460	AC ADAPTOR	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017461	APPLE PSU	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017462	RADIO	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017476	CLIPPERS PSU	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017477	STRAIGHTNERS	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017478	HAIR DRYER	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017479	CLIPPERS	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017480	HAIR DRYER	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017481	STRAIGHTNERS	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017482	HAIR DRYER	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017483	CURLING BRUSH	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017484	STRAIGHTNERS	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017485	HAIR DRYER	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017486	CURING LAMP PSU	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017487	TABLE LAMP	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS

 Total Appliances > **20**
HAIR & BEAUTY - THREADING ROOM

SF017492	LED LIGHT PSU	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017493	WAX POT	06/10/20	06/10/21	P	S	P 0.17	P >199	S	S	PASS

 Total Appliances > **2**
HAIR & BEAUTY - WAXING ROOM

SF017463	SPRAY TAN MOTOR	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS
SF017464	WAX POT	06/10/20	06/10/21	P	S	P 0.17	P >199	S	S	PASS
SF017465	WAX POT	06/10/20	06/10/21	P	S	S	P >199	S	S	PASS

 Total Appliances > **3**
Total Appliances For Report: 39