

PAT Report Passes And Fails For all Sites and Locations

CLIENT DETAILS	
Company Name:	Customer Ltd
Address:	Business Centre Burton on Trent DE11 9AA



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	Testsafe Ltd
Address:	Bretby Business Park Ashby Road Burton on Trent DE15 0YZ
Telephone:	01283 229873
Fax:	
Email:	sales@test-safe.co.uk
Cert Number:	
Order Number:	
File Name:	Testsafe_TS0000.PAT
Signature:	

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Retest Due	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
CUSTOMER LTD - ACCOUNTS OFFICE										
KH701721	6 WAY SP EXT LEAD	24/01/17	24/01/19	P	P	P 0.09	P >199	S	S	PASS
KH701722	FIG 8 LEAD	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701723	LABEL PRINTER	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701724	FIG 8 LEAD	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701725	AC DC ADAPTER	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701726	IEC LEAD	24/01/17	24/01/19	P	P	P 0.05	P >199	S	S	PASS
KH701727	PC	24/01/17	24/01/19	P	S	P 0.09	P >199	S	S	PASS
KH701728	6 WAY SP EXT LEAD	24/01/17	24/01/19	P	P	P 0.05	P >199	S	S	PASS
KH701729	AC ADAPTER	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701730	FIG 8 LEAD	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701731	AC DC ADAPTER	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701732	FIG 8 LEAD	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701733	LABEL PRINTER	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701734	6 WAY SP EXT LEAD	24/01/17	24/01/19	P	P	P 0.05	P >199	S	S	PASS
KH701735	FIG 8 LEAD	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
Total Appliances >										15

CUSTOMER LTD - DATA ENTRY										
PH622563	SURGE ADPT	06/12/16	06/12/18	P	P	P 0.02	P >199	S	S	PASS
PH622564	PHONE SWITCH	06/12/16	06/12/18	P	S	S	P >199	S	S	PASS
PH622565	TP LINK ROUTER	06/12/16	06/12/18	P	S	S	P >199	S	S	PASS
PH622566	CHRISTMAS TREE ADPT	06/12/16	06/12/17	P	S	S	P >199	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS
Key

P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Retest Due	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
PH622567	IEC LEAD	06/12/16	06/12/18	P	P	P 0.06	P >199	S	S	PASS
PH622568	PRINTER NO EXT EARTH	06/12/16	06/12/18	P	S	S	P >199	S	S	PASS

 Total Appliances > **6**
CUSTOMER LTD - RECEPTION

PH622560	IEC LEAD	06/12/16	06/12/17	P	P	P 0.06	P >199	S	S	PASS
PH622561	WATER COOLER	06/12/16	06/12/17	P	S	P 0.10	P >199	S	S	PASS
PH622562	BT ROUTER	06/12/16	06/12/18	P	S	S	P >199	S	S	PASS

 Total Appliances > **3**
CUSTOMER LTD - SALES OFFICE

KH701712	MOBILE CHARGER	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701713	6 WAY SP EXT LEAD	24/01/17	24/01/19	P	P	P 0.04	P >199	S	S	PASS
KH701714	FIG 8 LEAD	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701715	AC DC ADAPTER	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701716	AC ADAPTER	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701717	IEC LEAD	24/01/17	24/01/19	P	P	P 0.06	P >199	S	S	PASS
KH701718	PC	24/01/17	24/01/19	P	S	P 0.10	P >199	S	S	PASS
KH701719	IEC LEAD	24/01/17	24/01/19	P	P	P 0.06	P >199	S	S	PASS
KH701720	PC	24/01/17	24/01/19	P	S	P 0.09	P >199	S	S	PASS

 Total Appliances > **9**
CUSTOMER LTD - TEST & DESPATCH

PH622545	IEC LEAD	06/12/16	06/12/18	P	P	P 0.08	P >199	S	S	PASS
PH622546	PRINTER	06/12/16	06/12/18	P	S	P 0.07	P >199	S	S	PASS
PH622547	3 WAY ADPT	06/12/16	06/12/18	P	P	P 0.01	P >199	S	S	PASS
PH622548	FAN	06/12/16	06/12/17	P	S	S	P >199	S	S	PASS
PH622549	FAN	06/12/16	06/12/17	P	S	S	P >199	S	S	PASS
PH622550	FAN HEATER	06/12/16	06/12/17	P	S	S	P >199	S	S	PASS
PH622551	IEC LEAD	06/12/16	06/12/18	P	P	P 0.04	P >199	S	S	PASS
PH622552	PRINTER NO EXT EARTH	06/12/16	06/12/18	P	S	S	P >199	S	S	PASS
PH622553	FAN	06/12/16	06/12/17	P	S	S	P >199	S	S	PASS
PH622554	MOBILE PHONE CHARGER	06/12/16	06/12/17	P	S	S	P >199	S	S	PASS
PH622555	USB CHARGER	06/12/16	06/12/17	P	S	S	P >199	S	S	PASS
PH622556	IEC LEAD	06/12/16	06/12/18	P	P	P 0.09	P >199	S	S	PASS
PH622557	PRINTER	06/12/16	06/12/18	P	S	P 0.07	P >199	S	S	PASS
PH622558	HEATER	06/12/16	06/12/17	P	S	S	P >199	S	S	PASS
PH622559	SHREDDER	06/12/16	06/12/17	P	S	P 0.06	P >199	S	S	PASS
KH701736	AC DC ADAPTER	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701737	FIG 8 LEAD	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701738	LABEL PRINTER	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS
KH701739	IEC LEAD	24/01/17	24/01/19	P	P	P 0.05	P >199	S	S	PASS
KH701740	PC	24/01/17	24/01/19	P	S	P 0.08	P >199	S	S	PASS
KH701741	CHARGER	24/01/17	24/01/19	P	S	S	P >199	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS**Key**

P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Retest Due	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
--------------	-----------------------	-----------	------------	--------	----------	----------------------------	-----------------------	---------------	-----------------	----------------

Total Appliances > 21

Total Appliances For Report: 54